



# Woodland Fire Department

Community Risk Reduction Division

1000 Lincoln Avenue, Woodland, CA 95695 (530) 661-5857 [Risk.Reduction@cityofwoodland.gov](mailto:Risk.Reduction@cityofwoodland.gov)

## Technical Policy

<b>Title:</b> Fire Extinguishers		
<b>Technical Policy:</b> #TP-008	<b>Effective Date:</b> 4/1/2024	<b>Updated:</b> 02/01/2026
<b>Code References:</b> 2025 California Fire Code / CRR Title 19, Division 1		

### Standard

The Woodland Fire Department, Community Risk Reduction Division (“Division”) provides minimum standards requiring all businesses and apartment buildings to install and maintain a minimum of one 2A:10BC-rated fire extinguisher.

### Purpose

This construction standard details how and where fire extinguishers shall be installed and how they shall be maintained.

### Scope

This standard applies to all businesses and apartment buildings in the City of Woodland and Springlake Fire Protection District within the Woodland Fire Department’s (“Department”) jurisdiction.

### Application

All businesses and apartment buildings must install and maintain a minimum of one 2A:10BC rated fire extinguisher, mounted in an approved manner in an approved location (see Exhibit 1). Fire extinguishers shall be mounted so that the top of the extinguisher is between 3 feet and 5 feet from the finished floor.

Exhibit 1:



Classification 2-A:10-B:C